

<b>System Name</b>	<b>System ID</b>	<b>Sample Date</b>	<b>Lead (ppb)</b>	<b>Below Action Level</b>
Bay Mountain	CT0580041	06/06/17	<1	YES
		06/06/17	26.2	NO
		06/06/17	1.4	YES
		06/06/17	1.2	YES
		06/29/17	1.5	YES
		07/05/17	<1	YES
		07/04/17	<1	YES