

System Name	System ID	Sample Date	Lead (ppb)	Below Action Level
General Water	CT0320071	05/07/18	<1	Yes
		05/11/18	2.3	Yes
		05/09/18	<1	Yes
		05/08/18	<1	Yes
		05/10/18	<1	Yes
		05/10/18	<1	Yes
		05/02/18	<1	Yes
		05/05/18	<1	Yes
		05/02/18	<1	Yes
		05/08/18	<1	Yes
		05/18/18	<1	Yes