

<b>System Name</b>	<b>System ID</b>	<b>Sample Date</b>	<b>Lead (ppb)</b>	<b>Below Action Level</b>
<b>London Park</b>	<b>CT0670011</b>	<b>05/11/18</b>	<b>&lt;1</b>	<b>Yes</b>
		05/11/18	<1	Yes
		05/11/18	<1	Yes
		05/10/18	<1	Yes
		05/03/18	<1	Yes
		05/07/18	2.4	Yes
		05/03/18	<1	Yes
		05/04/18	<1	Yes
		05/11/18	<1	Yes
		05/14/18	<1	Yes
		05/14/18	<1	Yes