

System Name	System ID	Sample Date	Lead (ppb)	Below Action Level
Western	CT0473011	09/05/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	1	Yes
		09/06/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	<1	Yes
		09/05/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	2	Yes
		09/06/18	<1	Yes
		09/14/18	<1	Yes
		09/14/18	<1	Yes
		09/14/18	<1	Yes
		09/14/18	<1	Yes
		09/13/18	<1	Yes
		09/05/18	<1	Yes
		09/07/18	<1	Yes
		09/12/18	<1	Yes
		09/13/18	<1	Yes
		09/13/18	<1	Yes
		09/13/18	<1	Yes
		09/13/18	2	Yes
		09/13/18	1	Yes
		09/13/18	<1	Yes
		09/13/18	<1	Yes
		09/14/18	53	No
		09/14/18	<1	Yes
		09/14/18	<1	Yes
		09/05/18	1	Yes
		09/05/18	<1	Yes
		09/06/18	1	Yes
		09/05/18	<1	Yes
		09/06/18	<1	Yes
		09/05/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	1	Yes
		09/06/18	<1	Yes
		09/06/18	<1	Yes
		09/06/18	1	Yes
		09/21/18	<1	Yes
		09/21/18	<1	Yes

	09/21/18	<1	Yes
	09/21/18	<1	Yes
	09/20/18	<1	Yes
	09/21/18	<1	Yes
	09/20/18	2	Yes
	09/21/18	<1	Yes
	09/21/18	<1	Yes
	09/21/18	74	No
	09/25/18	<1	Yes
	09/24/18	<1	Yes
	09/25/18	2	Yes
	09/25/18	<1	Yes
	09/24/18	1	Yes
	09/27/18	2	Yes
	09/25/18	2	Yes
	09/26/18	<1	Yes
	10/01/18	2	Yes
	09/24/18	<1	Yes