

| System Name | System ID | Sample Date | Lead (ppb) | Below Action Level |
|--------------------|------------------|--------------------|-------------------|---------------------------|
| Guilford | CT0608011 | 07/31/18 | <1 | Yes |
| | | 08/01/18 | <1 | Yes |
| | | 07/31/18 | <1 | Yes |
| | | 07/30/18 | <1 | Yes |
| | | 08/08/18 | <1 | Yes |
| | | 08/07/18 | 1 | Yes |
| | | 08/06/18 | 1.1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/04/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/05/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | 1.4 | Yes |
| | | 08/06/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/06/18 | <1 | Yes |
| | | 08/07/18 | <1 | Yes |
| | | 08/11/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/09/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/13/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/09/18 | <1 | Yes |
| | | 08/10/18 | 2.3 | Yes |
| | | 08/10/18 | <1 | Yes |
| | | 08/13/18 | <1 | Yes |
| | | 08/10/18 | 4.6 | Yes |
| | | 08/09/18 | <1 | Yes |
| | | 08/08/18 | 1.3 | Yes |
| | | 08/30/18 | 2 | Yes |
| | | 09/07/18 | <1 | Yes |
| | | 08/30/18 | 2 | Yes |