

<b>System Name</b>	<b>System ID</b>	<b>Sample Date</b>	<b>Lead (ppb)</b>	<b>Below Action Level</b>
<b>Westchester East</b>	<b>CT0427021</b>	<b>08/17/18</b>	<b>2.6</b>	<b>Yes</b>
		08/16/18	<1	Yes
		08/16/18	1.9	Yes
		08/27/18	<1	Yes
		08/27/18	<1	Yes