

System Name	System ID	Sample Date	Lead (ppb)	Below Action Level
Plainfield	CT1090081	07/20/18	1.5	Yes
		07/20/18	1.4	Yes
		07/29/18	<1	Yes
		07/30/18	<1	Yes
		07/30/18	<1	Yes
		07/30/18	1.7	Yes
		07/30/18	<1	Yes
		07/30/18	<1	Yes
		07/29/18	<1	Yes
		07/31/18	1.3	Yes