

System Name	System ID	Sample Date	Lead (ppb)	Below Action Level
Plainfield	CT1090081	7/11/2019	2	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes
		7/11/2019	<1	Yes