

System	System ID	Sample Date	Lead(ppb)	Below Action Level
Riversedge	CT1609111	07/30/20	< 1	Yes
Riversedge	CT1609111	07/30/20	< 1	Yes
Riversedge	CT1609111	07/30/20	< 1	Yes
Riversedge	CT1609111	07/30/20	1	Yes
Riversedge	CT1609111	07/25/20	<1	Yes
Riversedge	CT1609111	07/29/20	7	Yes
Riversedge	CT1609111	07/30/20	< 1	Yes
Riversedge	CT1609111	07/30/20	< 1	Yes
Riversedge	CT1609111	07/29/20	< 1	Yes
Riversedge	CT1609111	07/25/20	1	Yes