

System Name	System ID	Sample Date	Lead (ppb)	Below Action Level
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/15/21	<1	Yes
South Coventry	CT0320051	07/12/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/10/21	14	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	3	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/14/21	<1	Yes
South Coventry	CT0320051	07/16/21	1	Yes
South Coventry	CT0320051	07/15/21	8	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/15/21	12	Yes
South Coventry	CT0320051	07/14/21	1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/15/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	07/16/21	3	Yes
South Coventry	CT0320051	07/12/21	1	Yes
South Coventry	CT0320051	07/10/21	<1	Yes
South Coventry	CT0320051	07/11/21	<1	Yes
South Coventry	CT0320051	07/16/21	<1	Yes
South Coventry	CT0320051	08/12/21	13	Yes